

5. ALL CONCRETE DESIGNATED AS STAMPED (EITHER RANDOM ASHLAR STONE RANDOM PATTERN OR SOLDIER COURSE PATTERN) AND LOCATED IN NON-VEHICLE AREAS SHALL BE COLOR HARDENED WITH QC COLOR HARDENER (QC CONSTRUCTION PRODUCTS COMPANY), OR BOMANITE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS. THE RANDOM ASHLAR STONE RANDOM PATTERN "NO RELIEF" (PER BOMANITE SPECIFICATIONS AND SIZES) WILL USE CLASSIC GRAY "L.M. SCOFIELD MATCH" AT A MINIMUM OF 60 POUNDS PER 100 SQUARE FEET. THE SOLDIER COURSE PATTERN WILL USE TILE RED AT A MINIMUM OF 60 POUNDS PER 100 SQUARE FEET. THE COLOR HARDENER SHALL BE FORMULATED FOR OPTIMUM SURFACE HARDENING, WITH AGGREGATES GRADED THROUGH A WIDE PARTICLE SIZE RANGE AND SELECTED FOR HARDNESS AND PURITY.
6. ALL CONCRETE DESIGNATED AS STAMPED (EITHER RANDOM ASHLAR STONE PATTERN OR SOLDIER COURSE PATTERN) AND LOCATED IN VEHICLE TRAFFIC AREAS SHALL BE COLOR HARDENED WITH EMERCHROME FLOOR HARDENER (L.M. SCOFIELD COMPANY), QC HEAVY DUTY HARDENER (QC CONSTRUCTION PRODUCTS COMPANY), OR BOMANITE. THE COLORS SHALL CORRESPOND TO THOSE LISTED IN THE PREVIOUS NOTE ON NON-TRAFFIC AREAS. THE HARDENER SHALL BE APPLIED AT A MINIMUM OF 120 POUNDS PER 100 SQUARE FEET. THE HARDENER SHALL BE FORMULATED WITH GRADED, NON-SLIP, NON-RUSTING, EMERY AGGREGATE.
7. EUCOBOND (EUCLID CHEMICAL COMPANY), OR AN APPROVED EQUAL, SHALL BE USED AS A CONCRETE BONDING AGENT BETWEEN ALL NEW CONCRETE AND EXISTING CONCRETE SURFACES.
8. THE AREA REPRESENTATIVE OF THE L.M. SCOFIELD COMPANY IS ROBERT TORRES, (1-916-715-2717). THE MAIN L.M. SCOFIELD OFFICE IS LOCATED AT 6533 BANDINI BOULEVARD, LOS ANGELES, CA 90040. THE AREA REPRESENTATIVE FOR QC CONSTRUCTION PRODUCTS COMPANY IS GEORGE LEE, PO BOX 599, MADERA, CA 93939, (1-925-439-0879). THE AREA REPRESENTATIVE FOR BOMANITE IS ANCHOR CONCRETE, 1750 MARIETTA WAY, SPARKS, NV 89431 (775-359-4969). THE AREA REPRESENTATIVE FOR BRICKFORM RAFCO PRODUCTS IS NEVADA CONCRETE SUPPLY, 1609 FREEPORT BLVD., SPARKS, NEVADA 89431 (775-331-5335).
9. ALL CONCRETE DESIGNATED AS EITHER RANDOM ASHLER STONE PATTERN OR SOLDIER COURSE PATTERN AND UTILIZING COLOR HARDENER, WHETHER LOCATED IN THE VEHICLE OR NON-VEHICLE AREA, SHALL RECEIVE A CLEAR LIQUID ANTIQUING RELEASE AGENT FROM EITHER L.M. SCOFIELD COMPANY, QC CONSTRUCTION PRODUCTS COMPANY, OR BOMANITE.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION RENO	
			GENERAL NOTES— STAMPED CONCRETE	DRAWING NO. R-104G (312)	
				DATE 01/04	
				PAGE 110	
APPROVED BY: G.S.		01/04			